


CERTIFICATE OF ANALYSIS
Reported by Alloway - Marion
 Chain of Custody attached


 Upper Sandusky WTP
 Attn: Aaron Schoenberger
 119 North 7th Street
 Upper Sandusky, OH 43351

Lab Project # 2511117
Received: 4/1/2025
Reported: 4/8/2025
Date/Time Sampled: 04/01/2025 09:00
Sampled By: Unknown
Sampled Matrix: Drinking Water
Containers: 3
Collection Method: Grab

Project Name:
Sample ID: EP002
Lab Sample # 2511117-01

Analyte	Results	Units	PQL	Analyst	Extraction Date	Analysis Start Date/Time
Analytical Method: EPA 353.2 Rev. 2.0		Preparation Method:			Validation Date:	4/8/2025
Nitrate/Nitrite-N	<0.10	mg/L	0.10	TLL		04/06/2025 06:23
Analytical Method: SM 4500-P E-11		Preparation Method: SM 4500P-B(5)-11			Validation Date:	4/8/2025
Phosphate, Total as P	0.45	mg/L	0.04	TLL		04/03/2025 13:11
Phosphate, Total as PO4	1.37	mg/L	0.12	TLL		04/03/2025 13:11
Analytical Method: EPA 200.7 Rev. 4.4		Preparation Method: EPA-200.7			Validation Date:	4/8/2025
Manganese, Total	<10	ug/L	10	PTP		04/03/2025 02:01

Analysis Certified By:



Rhonda C Morris

This report shall not be reproduced, except in its entirety, without the written approval of the laboratory.

The results presented on this Certificate of Analysis only reflect those parameters that were requested by the client on the chain of custody or other documentation received with the sample(s). The analytical results relate only to the items tested.



CERTIFICATE OF ANALYSIS
Reported by Alloway - Marion
 Chain of Custody attached

Upper Sandusky WTP
 Attn: Aaron Schoenberger
 119 North 7th Street
 Upper Sandusky, OH 43351

Lab Project # 2511117
Received: 4/1/2025
Reported: 4/8/2025
Date/Time Sampled: 04/01/2025 09:00
Sampled By: Unknown
Sampled Matrix: Water
Containers: 1
Collection Method: Grab


Project Name:

Sample ID: **Raw**
 Lab Sample # **2511117-02**

Analyte	Results	Units	PQL	Analyst	Extraction Date	Analysis Start Date/Time
Analytical Method: SM 5310B-00,14		Preparation Method:			Validation Date: 4/8/2025	
Total Organic Carbon	5.4	mg/L	0.7	BSR		04/04/2025 00:28

The matrix spike recovery is biased above method limits.

Analysis Certified By: _____



Rhonda C Morris

This report shall not be reproduced, except in its entirety, without the written approval of the laboratory.

The results presented on this Certificate of Analysis only reflect those parameters that were requested by the client on the chain of custody or other documentation received with the sample(s). The analytical results relate only to the items tested.

**CERTIFICATE OF ANALYSIS**
Reported by Alloway - Marion

Chain of Custody attached

Upper Sandusky WTP
Attn: Aaron Schoenberger
119 North 7th Street
Upper Sandusky, OH 43351


Lab Project # 2511117
Received: 4/1/2025
Reported: 4/8/2025
Date/Time Sampled: 04/01/2025 09:00
Sampled By: Unknown
Sampled Matrix: Drinking Water
Containers: 1
Collection Method: Grab

Project Name:

Sample ID: Tap
Lab Sample # 2511117-03

Analyte	Results	Units	PQL	Analyst	Extraction Date	Analysis Start Date/Time
Analytical Method: SM 5310B-00,14		Preparation Method:			Validation Date: 4/8/2025	
Total Organic Carbon	1.8	mg/L	0.7	BSR		04/04/2025 01:25

Analysis Certified By: _____



Rhonda C Morris

This report shall not be reproduced, except in its entirety, without the written approval of the laboratory.

The results presented on this Certificate of Analysis only reflect those parameters that were requested by the client on the chain of custody or other documentation received with the sample(s). The analytical results relate only to the items tested.