

Location Information					
Unique Service Line ID	Street Number	Street Name	City	Zip Code	County
A Unique ID by the public water	Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location is not use addresses for their location identifier, other options could include GPS coordinates, landmark, in				
Example 1	1234	Test St.	Test City	88888	Test County
1	1502	Main St	Braceville	44444	Adams
2	1268	Main St	Braceville	44444	Adams
2069	217	ASH DR	Upper Sandusky	43351	Wyandot
1592	223	ASH DR	Upper Sandusky	43351	Wyandot
1597	224	ASH DR	Upper Sandusky	43351	Wyandot
1593	225	ASH DR	Upper Sandusky	43351	Wyandot

Latitude	Longitude	In Asset Management	Asset End Date	System-Owned Portion Service Line Material Classification	If Non-Lead
					Was Material Ever Previously Lead?
Identifiers are required for lead and galvanized requiring replacement. If the system does intersection, block, or other details to specify service line locations.				If "Non-Lead Other", describe in Comments field	Important for determining if service line requires replacement
##.#####	-##.#####	Yes, No, Unknown	mm/dd/yyyy		Yes
41.2566	-80.9806	No	1/1/2023		No
41.2560	-80.9820	Yes			No
40.8390	83.2821			Non-Lead - Copper	No
46.4472	83.2827			Non-Lead - Copper	No
40.8391	83.2825			Non-Lead - Copper	No
40.8389	83.2827			Non-Lead - Copper	No

Inventory

System-Owned Portion

Service Line Installation Date	Is the Service Line Metered	Service Line Use	Service Line Size	Service Line Length	Basis of Material Classification	Was the Service Line Material Field Verified?
Estimated date when the service line was installed or replaced	Service Line Metered or Not Metered	Drinking, Non-Drinking, Combination	Diameter in inches	Length in Feet	Select option from drop down list. If "Other," describe in the Notes field	
3/19/1999	Yes	Drinking	1.50	6	Field inspection only with no records	No
4/2/2005	Yes	Drinking	1.25	6	Service line diameter is greater than 2 inches	Yes
	Yes	Combination	2.50	8	Installation record (e.g., tap card)	No
10/16/1985					Installation record (e.g., tap card)	
7/28/1993					Installation record (e.g., tap card)	
1/1/1995					Installation date is after the lead ban	
7/23/1985					Installation record (e.g., tap card)	

		Custo		
If Yes in Column W...		Customer-Owned Portion Service Line Material Classification	Service Line Installation Date	Basis of Material Classification
Describe the Field Verification Method	Enter the Date of Field Verification			
If Other, describe in the Notes field	Estimated date of field verification or date that the record was updated	If "Non-Lead Other", describe in Comments field	Estimated date when the service line was installed or replaced	If Other, describe in the Notes field
			7/4/1905	Previous materials evaluation
Mechanical Excavation at 1	5/2/2019		7/12/1991	Water sampling only with no records
			10/1/2001	Installation record (e.g., tap card)
		Non-Lead - Copper		
		Non-Lead - Copper		
		Non-Lead - Copper		
		Non-Lead - Copper		

Customer-Owned Portion			Other	When to Assign				Lead
Was the Service Line Material Field Verified?	If Yes in Column AE...							
	Describe the Field Verification Method	Enter the Date of Field Verification						
	If Other, describe in the Notes field	Estimated date of field verification or date that the record was updated						
Yes	Visual inspection at the meter pit	5/1/2019						
No								
Yes	Customer self-identification	7/2/2017						
Yes	Visual inspection at the meter pit	5/1/2022						
Yes	Visual inspection at the meter pit	5/1/2022						
Yes	Visual inspection at the meter pit	5/1/2022						
Yes	Visual inspection at the meter pit	5/1/2022						

Comments
Is there a Lead Connector?
Please use this section to record any comments or notes associated with a service line.
Domestic tapped off fire suppression line
Ordinance 931.07-1969 service line must be copper
Ordinance 931.07-1969 service line must be copper
identified during meter change program
identified during meter change program
identified during meter change program